



FLOOR PLAN
SCALE 1:100

FLOOR AREA = 93.97m²

FINISHES SCHEDULE	
ELEMENT	SPECIFICATION
STORE ROOM FLOOR	FLOOR FINISHES SHALL BE POWER FLOATED AND BE COATED TWO COATS OF APPROVED DUST SEALER.
MV SWITCH ROOM FLOOR	FLOOR FINISHES SHALL BE POWER FLOATED AND BE COATED TWO COATS OF APPROVED DUST SEALER.
CONTROL ROOM FLOOR	THE CONTROL ROOM CONCRETE FLOOR [UNDER THE RAISED ACCESS FLOORING] SHALL HAVE THINNED POLYBOND APPLIED IN 2 COATS IN ACCORDANCE WITH THE MANUFACTURER'S INSTRUCTIONS.
TOILET FLOOR	ALTRU CLASSIC 2.5mm WITH 150mm FORMED SKIRTING OR EQUIVALENT AGREED.
RAISED ACCESS FLOOR	RAISED ACCESS FLOOR SHALL BE IN ACCORDANCE WITH BS EN12825: 2001. ELEMENTS SHALL BE CLASS 6 IN ACCORDANCE WITH TABLE 1 OF BS EN12825.
CEILINGS UNDER HOLLOWCORE	POLYBOND SEALER FOLLOWED BY 2No. COATS OF WHITE EMULSION PAINT
WALLS INTERNAL	FAIRFACED CONCRETE BLOCKWORK WITH POLYBOND SEALER FOLLOWED BY 2No. COATS OF WHITE EMULSION PAINT.
WALLS EXTERNAL	SELF COLOURED NAP PLASTER
WC WALLS	WC WALLS TO HAVE A SKIMMED PLASTER FINISH PAINTED IN WASHABLE "FLECK" PAINT OR OTHER APPROVED HEAVY DUTY EASY CLEAN TREATMENT. 3 No. ROWS OF 150x150 MATT WHITE WALL TILES SHALL BE PROVIDED ABOVE THE WHB FOR SPLASHBACK.

NOTE:
EXTERNAL DOORS TO BE GALVANISED STEEL FINISHED WITH GALVACOAT OR EQUIVALENT. COLOUR RAL 6020 CHROME GREEN. ALL EXTERNAL DOORS TO HAVE 50mm ROCKWOOL RW4 FLEXIBLE/SEMI-RIGID OR APPROVED INSULATION



ScottishPower Renewables
320 St Vincent Street
Glasgow
G2 5AD

Email: info@scottishpowerrenewables.com
Web: www.scottishpowerrenewables.com

Notes

- This drawing is the property of ScottishPower Renewables UK Ltd. It is a confidential document and must not be copied, used, or its contents divulged without prior written consent.
- Scale 1:100 @ A3

Rev.	Date	By	Amendments

Project

BARNESMORE WINDFARM
REPOWERING

Title

PROPOSED IPP
CONTROL BUILDING
PLAN

FIGURE 2.12(a)

Issue Details

Designed: JOD	Information	X
Drawn: AMcC	Approval	
Checked: S.M.	Tender	
Approved: D.K.	Construction	
Scale: 1:100 (A3)	Record	

Office Use Only

Drawing Number:	5952-800-812
Date:	30/10/2019
Rev.	