

Appendix 9.2 – Calculated Noise Immission Levels (SG6.0 turbine)

Contents

Table 9.2 Predicted Noise Immission Levels dB $L_{A90,10min}$ against 10m Wind Speed for SG-6.0-155PD turbines

This page is intentionally blank.

Appendix 9.2: Calculated Noise Immission Levels

Table A9.2 – Predicted Noise Immission Levels dB LA90,10min against 10m Wind Speed for SG-6.0-155PD turbines

Receptor	4m/s	5m/s	6m/s	7m/s	8m/s	9m/s	10m/s	11m/s	12m/s
Shielpark	24	29	32	32	32	32	32	32	32
Monksfoot	29	35	37	37	37	37	37	37	37
Carmacoup Fm Cott	25	31	33	33	33	33	33	33	33
Viaduct Cottage	26	31	34	34	34	34	34	34	34
Bungalow Cottage	25	30	33	33	33	33	33	33	33
Longhouse Cottage	25	31	33	33	33	33	33	33	33
Braeface Cottage	26	31	34	34	34	34	34	34	34
Hillview Crescent	26	31	34	34	34	34	34	34	34
Hazelside Farm	24	30	32	32	32	32	32	32	32
Station House	24	29	32	32	32	32	32	32	32
Blackwood Cottage	23	29	31	31	31	31	31	31	31
Scrogton	21	27	29	29	29	29	29	29	29
Scrogtonhead	23	28	31	31	31	31	31	31	31

This page is intentionally blank.